

DIGITAL PANEL METER / D

240VAC Display Only Version

This document is a summary only and must be read in conjunction with the Installation and Operating Guidelines Document.

This model operates with a 240VAC supply.

The defrost input will force the meter to display **df** in place of the temperature for the duration of a signal being applied.

This model does not have the following features mentioned in the installation and operating guidelines.

- 1) It can not be used as a slave to a TACm via the Complog output.
- 2) It will not operate at 12Vdc.
- 3) The Remote Board is not compatible with this model.
- 4) The unit is not programmable.
- 5) Temperature, Alarm and Defrost control functions are not available.

